


Energy Audit Report

for






R.V.R. & J.C. College of Engineering, Guntur.

By



Bhumitra Energy Auditing and Consultancy Pvt. Ltd.

For Bhumitra		For RVR&JC
Prepared By	Reviewed and Approved By	Accepted By
		

Think for future! Think green! Print this document only, if it is really required.

Please do not make multiple hard copies of this document ...



TABLE OF CONTENTS

Table of Contents.....	2
Communication	4
Acknowledgements.....	5
Limitations / Disclaimer	6
Abbreviations	7
List Of Tables	8
List of Figures	9
List of Findings.....	10
1.0 Executive Summary	11
1.1 Summary of Estimated Losses in RVR&JC	11
1.2 Summary of Findings & Recommendations for RVR&JC.....	12
2.0 Introduction	16
2.1 A Brief About RVR & JC College of Engineering	16
2.2 About Bhumitra	17
2.2.1 The Consultant Team.....	17
2.2.2 List of Instruments Used.....	18
2.3 Scope of Audit	19
2.4 Layout of RVR & JC College of Engineering	20
2.5 Electrical System Description.....	20
3.0 Analysis of Data, Opportunities and Proposals.....	22
3.1 Data Collection and Analysis	22
3.2 Analysis of Power Bills.....	23
3.2.1 Additional Amount paid due to Low Power factor (LPF).....	24
3.2.2 Additional Amount paid due to Higher Contracted Maximum Demand (CMD).....	27
3.3 RVR&JC Lighting and Fans	30
3.3.1 Savings by replacing In-efficient 40W old TL with LED Light	31
3.3.2 Savings by replacing In-efficient 36W old TL with LED Light	32
3.3.3 Losses due to In-efficient CFL Bulbs	33
3.3.4 Losses due to In-efficient 85W Ceiling Fans	34
3.3.5 Losses due to In-efficient 60W Ceiling Fans	35
3.4 Demand side Management Analysis	36

3.5	Analysis of Feeders with Power Analyzers	37
3.5.1	Analysis of Transformers Feeders with Power Analyzer.....	37
3.5.2	Analysis of Distribution Feeders with Power Analyzer	38
3.5.3	Electrical Energy Management and Control.....	39
3.5.4	Electrical Energy Balance.....	40
3.6	Capacitor Bank Health.....	41
3.7	Expansion of Solar Plant Vs Replacement of Ceiling Fans with BLDC Ceiling Fans	42
3.8	Air Conditioning	43

COMMUNICATION

R.V.R. & J.C. College of Engineering
Sri. Rayapati Gopala Krishna Garu Secretary & Correspondent
R.V.R. & J.C. College of Engineering – Chandramoulipuram, Chowdavaram, Guntur – 522019.

Bhumitra Energy Auditing and Consultancy Pvt. Ltd. (Bhumitra)	
N D Raghuram Chief Consultant BEE Certified Energy Auditor : EA-11516	Mobile : 09848313009 raghuram@bhumitra.com
Bhumitra Energy Auditing and Consultancy Pvt. Ltd. Branch Office : H.No. 2 – 14 – 122, Plot No. 22, 5 Lane, Syamalanagar – 522 006; Andhra Pradesh, India. Fax : +91 863 2236041 (Manual); bhumitra@bhumitra.com ; www.bhumitra.com .	

ACKNOWLEDGEMENTS

I would like to express my Grateful thanks to the Management of R.V.R. & J.C. College of Engineering and Nagarjuna Education Society, Specifically to Sri Rayapati Gopala Krishna Garu, Secretary & Correspondent for this opportunity given to us.

I would like to sincerely appreciate and thank the key people, **Dr. K. Srinivasu** (Principal), Audit Committee members Mr. G Bhaskara Rao, Dr. P. Gouri Sankar, Dr. P. Rohinikumar, Mr. B.V Vasantha Rao, Mr. M. Srikanth Kumar, Mr. Ch. Devaraj, Ms. M. Sudheera who are always available for me in sharing the data. The study would not have come up so well without their help.

The Involvement of Management and Their Commitment to Environment Sustainability is clearly demonstrated in every stage of the audit by the way of full cooperation and total involvement from top to bottom. It is this commitment that helped me deliver an HONEST report without trouble.

The help rendered by the Technicians and Electrical Maintenance in-charge Mr. Rama Koteswara rao is worth mentioning.

This section would be incomplete without mention of support rendered by my Team by working tirelessly without getting fed up with my numerous corrections and changes to bring out reasonably accurate and Honest report.

This section would be incomplete without mention of support rendered by Registrar Dr NV Srinivas, Registrar and Electrical HOD Dr K Chandra Sekhar for guiding their staff in promptly delivering requisite data and helping us in smooth conduct of audit.

I once again thank each and every one and wish that this association should go a real long way in contributing for a Sustainable Environment.

Each unit saved is two units generated and conservation is continuous process with various new technologies and operating philosophies coming in continuously. With increasing thrust on conservation RVR&JC has mandated for this energy Audit.

LIMITATIONS / DISCLAIMER

We have taken maximum care in ensuring the results to be accurate. Bhumitra shall be only responsible to correct any unfortunate discrepancies and compensate any direct advantage if enjoyed by Bhumitra. The reporting format is intellectual property of Bhumitra. Sharing of the document or content shall be judicious to avoid any duplication and misuse and shall be with permission of Bhumitra if it has to be shared externally.

ABBREVIATIONS

AC	Air Conditioner	NA	Not Applicable
Approx.	Approximate	No's	Numbers
Atm	Atmosphere	OU	Observed Line Voltage
BLDC	Brush Less Direct Current	OV	Observed phase Voltage
Diff	Difference	OA	Observed Current
EB	Electronic Ballast	OKW	Observed Kilo Watt
Eff	Efficiency	OPF	Observed Power Factor
HP	Horse Power	Pvt	Private
Hrs.	Hours	Qty	Quantity
Inst.Name	Instrument Name	Reqd	Required
IS	Indian Standard	S.No	Serial Number
kwh	Kilo Watt Hour	THD	Total Harmonic Distortion
Max	Maximum	wh	Watt Hour
mts	Meters	Yrs	Years

LIST OF TABLES

Table 1 : Last 1 Year Power Bills	23
Table 2 : Additional amount paid due to Low Power Factor	24
Table 3 : Additional Payment due to LPF – Annual Summary	26
Table 4 : Additional Payment due to CMD – Annual Summary	27
Table 5 : Additional Payment due to CMD – Annual Summary	29
Table 6 : RVR&JC Lighting Load Details	30
Table 7 : Savings by replacing In-efficient 40W old TL with LED Light	31
Table 8 : Savings by replacing In-efficient 36W old TL with LED Light	32
Table 9 : Losses due to In-efficient CFL Bulbs	33
Table 10 : Losses due to In-efficient 85W Ceiling Fans	34
Table 11 : Losses due to In-efficient 60W Ceiling Fans	35
Table 12 : Savings due to reduction of KVA Demand	36
Table 13 : Power Analyzer readings of Transformer Feeders	37
Table 14 : Loading of Transformer Feeders	37
Table 15 : Power Analyzer readings of the MCC Feeders	38
Table 16 : Un-Balanced loading of distribution Feeders	38
Table 17 : Capacitor Banks health	41
Table 18 : Analysis of Solar Power Plant Expansion	42
Table 19 : Analysis of In-Efficient Ceiling Fans with BLDC Ceiling Fans	42
Table 20 : Summary of Split and Window Air Conditioners building wise	43
Table 21 : Savings with Dual Inverter Type Air Conditioners	44

LIST OF FIGURES

Figure 1 : Layout of RVR & JC	20
Figure 2: Trends of kVAh Consumption Trend	25
Figure 3: Power Factor Trend	25
Figure 4: kWh Units Trend	26
Figure 5 : RVR & JC Recorded KVA Demand Trend	28
Figure 6 : RVR & JC Additional amount paid due to CMD	28

LIST OF FINDINGS

Finding 1 : Additional Amount being paid by RVR & JC to APTC due to Low Power Factor (LPF).....	24
Finding 2 : Additional Amount being paid by RVR & JC to APTC due to Higher Contracted Maximum Demand.....	27
Finding 3 : Savings by replacing In-efficient 40W old TL with LED Light.....	31
Finding 4 : Savings by replacing In-efficient 36W old TL with LED Light.....	32
Finding 5 : Losses due to In-efficient CFL Bulbs	33
Finding 6 : Losses due to In-efficient 85W Ceiling Fans.....	34
Finding 7 : Losses due to In-efficient 60W Ceiling Fans.....	35
Finding 8 : Demand Side Management	36
Finding 9 : Un-Balanced Loading on Transformers.....	37
Finding 10 : Un-Balanced Loading on Feeders	38
Finding 11 : Absence of Energy Monitoring and Control Mechanism.....	39
Finding 12 : Absence of Energy Balance Mechanism	40
Finding 13 : Capacitor Banks Health.....	41
Finding 14 : Expansion of Solar Power Plant Vs BLDC Ceiling Fans.....	42
Finding 15 : Savings with Dual Inverter Type Air Conditioners.....	43

1.0 EXECUTIVE SUMMARY

1.1 SUMMARY OF ESTIMATED LOSSES IN RVR&JC

Total Annual Energy Loss in RVR&JC	kWh	3,18,823
Approx. Total Annual Loss in RVR&JC including CMD	INR in Lakhs	35.89

Note: Projections made in Sections 1.1 above are only approximate calculations based on RVR&JC estimated losses. This is to give a rough Idea of losses happening in respective areas. Detailed analysis of each finding helps in exactly arriving at losses and steps to be implimented.

1.2 SUMMARY OF FINDINGS & RECOMMENDATIONS FOR RVR&JC

Finding : 1		Page No 24
: Additional Amount being paid by RVR & JC to APTC due to Low Power Factor (LPF)		
Annual Energy Loss	kVAh	7600
Annual Loss	INR in Lakhs	0.58
Recommendation: As the power factor is maintained very well additional amount paid due to low power factor is not significant amount, it is recommended to go for automatic power factor correction equipment to reduce active power loss and leading power factor.		

Finding : 2		Page No 27
: Additional Amount being paid by RVR & JC to APTC due to Higher Contracted Maximum Demand		
Average Monthly Additional Amount paid	INR in Lakhs	0.78
Recommendation: Reduce Demand by employing the Energy Efficient equipment to reduce Demand and kVAh units consumption simultaneously.		

Finding : 3		Page No 31
: Savings by replacing In-efficient 40W old TL with LED Light		
Annual Energy Loss	kWh	11,236
Annual Energy Loss	INR in Lakhs	0.86
Annual Loss due to Demand	INR in Lakhs	0.34
Net Annual Loss	INR in Lakhs	1.20
Investment	INR in Lakhs	1.23
Simple Payback Period	Years	1.0
Recommendation: It is recommended to go for LED lighting as the payback is very quick.		

Finding : 4**Page No 32****: Savings by replacing In-efficient 36W old TL with LED Light**

Annual Energy Loss	kWh	43,484
Annual Energy Loss	INR in Lakhs	3.33
Annual Loss due to Demand	INR in Lakhs	1.29
Net Annual Loss	INR in Lakhs	4.61
Investment	INR in Lakhs	6.0
Simple Payback Period	Years	1.3

Recommendation: It is recommended to go for LED lighting as the payback is very quick.

Finding : 5**Page No 33****: Losses due to In-efficient CFL Bulbs**

Annual Energy Loss	kWh	12,050
Annual Energy Loss	INR in Lakhs	0.92
Annual Loss due to Demand	INR in Lakhs	0.08
Net Annual Loss	INR in Lakhs	1.0
Investment	INR in Lakhs	0.73
Simple Payback Period	Years	0.7

Recommendation: It is recommended to go for LED lighting as the payback is very quick.

Finding : 6**Page No 34****: Losses due to In-efficient 85W Ceiling Fans**

Annual Energy Loss	kWh	1,29,678
Annual Energy Loss	INR in Lakhs	9.9
Annual Loss due to Demand	INR in Lakhs	3.85
Net Annual Loss	INR in Lakhs	13.77
Investment	INR in Lakhs	42.2
Simple Payback Period	Years	3.06

Recommendation: To reduce the demand and annual energy losses it is recommended to change the existing ceiling fans with BLDC ceiling fans in phased manner.

Finding : 7**Page No 35****: Losses due to In-efficient 60W Ceiling Fans**

Annual Energy Loss	kWh	21,829
Annual Energy Loss	INR in Lakhs	1.7
Annual Loss due to Demand	INR in Lakhs	0.65
Net Annual Loss	INR in Lakhs	2.32
Investment	INR in Lakhs	12.3
Simple Payback Period	Years	5.3

Recommendation: To reduce the demand and annual energy losses it is recommended to change the existing ceiling fans with BLDC ceiling fans in phased manner.

Finding : 8**Page No 36****Demand side Management**

Recommendation: During the college opening and closing hours the demand generated by the existing 500kWp solar power plant is about 20% i.e., 100KVA. Even from the power bills, before and after solar plant, 60-90 KVA demand difference is seen. It is recommended to reduce the CMD immediately after understanding the risk of low generation due to weather.

Finding : 9**Page No 37****Un-Balanced loading on Transformers**

Recommendation: It is recommended to go for single transformer of higher capacity and efficiency or synchronize the three transformers to avoid un-balanced loading and over loading on transformers

Finding : 10**Page No 38****Un-Balanced loading on Distribution Feeders**

Recommendation: It is recommended to balance the load in three phases to minimize the losses and overloading of phases.

Finding : 11**Page No 39****: Absence of Energy Monitoring and Control Mechanism**

Recommendation: Feeder wise energy monitoring system with import/export feature for meter and monitoring of all the parameters like MD, PF, kVAh, kWh, kVARh, Voltage to monitor energy consumed and control demand is required.

Finding : 12

Page No 40

: Absence of Energy Balance Mechanism

Recommendation: Feeder wise energy monitoring system with automatic energy balance on daily basis shall be established.

Finding : 13

Page No 41

: Capacitor Banks health

Recommendation: Some Capacitors have zero and low currents, we may remove them and Install proper rating of Capacitor to manage Power Factor.

Finding : 14

Page No 42

Expansion of Solar Plant Vs Replacement of Ceiling Fans with BLDC Ceiling Fans

Recommendation: It is recommended to go with BLDC ceiling fans to reduce demand, also payback and execution time is quick. Where as in expansion of solar power plant it requires more Land and demand may not be matched due to low weather conditions at times.

Finding : 15

Page No 44

: Savings with Dual Inverter Type Air Conditioners

Annual Energy Loss	kWh	1,00,547
Annual Energy Loss	INR in Lakhs	7.7
Annual Loss due to Demand	INR in Lakhs	5.3
Net Annual Loss	INR in Lakhs	13
Investment	INR in Lakhs	100
Simple Payback Period	Years	7.7

Recommendation: It is recommended to go with Dual Inverter type ACs to reduce demand in phased manner.

Note:

All the findings presented above are not independent. Implementation of one finding may take care of other finding. All the findings and recommendations are based on available data and assumptions. These are very indicative and detailed study, analysis and proper engineering is required for implementation of any of recommendations.

2.0 INTRODUCTION

2.1 A BRIEF ABOUT RVR & JC COLLEGE OF ENGINEERING

Rayapati Venkata Ranga Rao and Jagarlamudi Chandramouli (R.V.R. & J.C.) College of Engineering, Chowdavaram, Guntur trains undergraduate and postgraduate students in Engineering and Management for award of degree from Acharya Nagarjuna University. Established by the renowned Nagarjuna Education Society (1967) in the year 1985, the College drew its initial impetus from Peoples Representatives, local doctors, charitable trusts and commercial houses of Guntur District. Today, it enjoys flagship status among the eight constituent institutions, that are governed by Nagarjuna Education Society. The founder-members of Nagarjuna Education Society and their successors have provided abundant inputs to turn a mere 3-course-180-intake College into a 14-course-1200-intake edifice by the Silver Jubilee Year.

The premier status of the institution is made possible by sticking to core-principles of student-focus, Human Resource Development and emphasis on total quality. Training the students beyond the defined borders of the curriculum is a basic emphasis, the college dearly practices. The college periodically tests its own standards and standing among the fraternity of colleges, securing Accreditation from National Board of Accreditation, AICTE in 1998, 2002, 2007, 2012, & 2017. The A.P. State Council of Higher Education (APSCHE) too awarded the second-best rating in 'Academic Audit and Grading' in 2004. The Awards of Best Performing U.G. College in the university examinations, consecutively for three years and a place among the 'Top-100 Engineering Colleges in the country are major achievements. The College practices the modesty of looking for new starting lines than be content with the finishing lines reached. They humbly admit, they have miles and miles to go before they complete their mission.

2.2 ABOUT BHUMITRA

Bhumitra Energy Auditing and Consultancy Pvt. Ltd. (Bhumitra) is an integrated service provider in the areas of energy audit, total energy management solutions, reliability audit, consultancy services for Greenfield and efficiency improvement projects. The company is setup by Mr. ND Raghuram, who is having vast and varied experience of about 20 years in Power, Green Energy, Industrial Automation, CDM and ISO. Bhumitra is setup by him with passion towards Environment and Energy Conservation.

Bhumitra is setup with a primary motto to conserve environment and energy and thereby contribute for a better and greener tomorrow

Vision : Tomorrow Should be Better

Mission : Reduce Damage being caused to Environment by providing Eco Friendly Services and Products.

Values : Honesty, Commitment and Hard Work ... In what We think, We talk and We do...

2.2.1 THE CONSULTANT TEAM

Energy audit of the plant was carried out by Bhumitra Energy Auditing & Consultancy pvt Ltd, Guntur.

1	Mr. Durga Raghuram Nagalla	<i>BEE Certified Energy Auditor (EA-11516) & Chief Consultant</i>
2	Mr. Ganesh Kumar Pagadala	<i>Sr. Consultant & Energy Auditor</i>
3	Mr. B. Gopi	Technical Asst, Electrical
5	Mr. K. Punnarao	Technical Asst, Electrical

2.2.2 LIST OF INSTRUMENTS USED

S.No	Inst.Name	Make	Model
1	3-Phase Power Analyzer	AEMC	Powerpad 3945-B
2	1-Phase Power Analyzer	AEMC	Powerpad Jr. 8230
3	AC/DC Tong Tester	Ideal	61-775
4	Digital Multi meter	Ideal	61-486
5	Thermo-Anemometer + IR Thermometer	Extech Instruments	HD300
6	Lux Meter	Testo	Testo 540
7	Power guard	Meco	PG09
8	Infrared Thermometer	Ideal	61-685

2.3 SCOPE OF AUDIT

The main objective of this Energy Audit is to identify the energy conservation opportunities and to suggest measures to minimize energy losses so that energy utilization could be improved.

The broad scope of work for the energy audit is as follows ...


- ❖ Qualitative and quantitative study of all components of energy payable i.e. kW, kWh, kVAr, MD, PF and harmonics etc.
- ❖ Study of system network, rating/capacities, operational pattern and energy metering systems.
- ❖ Study of Capacitor Banks positioning, adequacy, Energy dissipation in capacitor banks and measures to minimize losses.
- ❖ Analysis for performance of connected/drive equipment in respect of energy consumption and output.
- ❖ Suggestion/measures to reduce transmission losses/ Distribution feeder losses for energy conservation.
- ❖ Study and analysis on usage of equipment like transformers, Air Conditioners etc.

It is intended that the auditor's report will bring out suggestions where wastage can be controlled with or without additional investment.

It is intended that the auditor's report will include sample analysis of energy flow in the network and on board the driving asset and indicate scope of improvement in efficiency of the utilization of available energy.

2.4 LAYOUT OF RVR & JC COLLEGE OF ENGINEERING

Figure 1 : Layout of RVR & JC College of Engineering



ELECTRICAL SYSTEM DESCRIPTION

RVR & JC College of Engineering is sited at Chandramoulipuram, Chowdavaram, Guntur District.

The campus has 11KV/433V Sub-Station with 3 Nos of power distribution transformers

1. 200 KVA of Trans Allieds make,
2. 315 KVA of Vijay Power Control Systems make
3. 315 KVA of Sri Sai Ram Electricals make

11KV Power Supply is from 33KV/11KV APTC Sub-Station at Dasaripalem near Chowdavaram.

Standby Generators are also available to serve during power outages.

The Campus has capacity of 250 kVAr capacitor bank, each of 25 KVAr rated.

Main PCC has 5 feeders namely Main Block, HITECH Block, Silver Jubilee Block, CYBER Block and DIGITAL Block. For above 5 Feeders cables laid from PCC at Power House to respective blocks MCCs for operations and control.

The distribution feeders from MCCs to Buildings are in different sizes ranging from 4 Sq. mm to 250 Sq. mm depending on Load/machinery.

3.0 ANALYSIS OF DATA, OPPORTUNITIES AND PROPOSALS

Data Collected from various sources and that sampled and measured through power analyzers is further processed and analyzed and correlated with standards and good practices. Based on the same opportunities for improvement are identified and presented as findings in this section. Any improvement opportunities identified, that helps in improving the system efficiency are also presented in this section.

3.1 DATA COLLECTION AND ANALYSIS

Collection of reliable data is foremost important task in Energy Audit of any process. This required data is collected in following ways.

- From records like monthly bills, log books equipment operating manuals, test certificates etc.
- Measurements and Observations: Three phase and Single-phase power analyzers are employed to take practical measurements of energy data and cross verification of assumed data. This is the key data that has helped in identifying key opportunities.

In cases where data is not specifically available data is conservatively assumed during analysis.

The data collected and the analysis is presented in following sections.

3.2 ANALYSIS OF POWER BILLS

Last 1 year of energy bills are collected and contents tabulated in **Table 1**. This data is analysed by plotting trends, same are discussed and findings are presented in this section.

Table 1 : Last 1 Year Power Bills

Month	kWh	kVAh	PF	Bill Amount	Max Recd MD	Jayalakshmi Power		Power Consumption in kVAh units	Total Bill Amount
	APTC							Total	
Feb-20	27272	28250	0.97	429604	365			28250	429604
Jan-20	52322	52772	0.99	608800	104			52772	608800
Dec-19	80156	22169	0.98	364903	390	59815	449445	81984	814348
Nov-19	62584	10000	0.99	269575	455	53316	401589	63316	671164
Oct-19	98072	10457	0.98	281591	418	89799	674066	100256	955657
Sep-19	82180	10503	0.99	282907	420	72605	545708	83108	828615
Aug-19	104476	105828	0.99	1074270	512			105828	1074270
Jul-19	101400	103344	0.98	1100749	561			103344	1100749
Jun-19	67012	67456	0.99	755945	464			67456	755945
May-19	82096	13349	0.99	220709	425	69803	529453	83152	750162
Apr-19	105256	107688	0.98	1187969	555			107688	1187969
Mar-19	83724	43555	0.98	53950	409	41557	315950	85112	369900

Finding 1 : Additional Amount being paid by RVR & JC to APTC due to Low Power Factor (LPF)

3.2.1 ADDITIONAL AMOUNT PAID DUE TO LOW POWER FACTOR (LPF)

The Billing system is kVAh billing hence any instantaneous fall in pf impacts kVAh count instantaneously and hence billing. Even if the Average pf is leading or on other words even if the reactive energy is pumped into grid at times it is treated as UPF.

Table 2 below shows the monthwise summary of additional kVAh consumed and additional amount being paid.

Table 2 : Additional amount paid due to Low Power Factor

Month	KWh	KVAh	Total Bill Amount	derived PF	derived unit cost	KVAH-KWH	Additional Amount paid
Feb-20	27272	28250	429604	0.97	7.65	978	7482
Jan-20	52322	52772	608800	0.99	7.65	450	3443
Dec-19	80156	22169	364903	0.98	7.65	0	0
Nov-19	62584	10000	269575	0.99	7.65	0	0
Oct-19	98072	10457	281591	0.98	7.65	0	0
Sep-19	82180	10503	282907	0.99	7.65	0	0
Aug-19	104476	105828	1074270	0.99	7.65	1352	10343
Jul-19	101400	103344	1100749	0.98	7.65	1944	14872
Jun-19	67012	67456	755945	0.99	7.65	444	3397
May-19	82096	13349	220709	0.99	7.65	0	0
Apr-19	105256	107688	1187969	0.98	7.65	2432	18605
Mar-19	83724	43555	53950	0.98	7.65	0	0




Figure 2: Trends of kVAh Consumption Trend




Figure 3: Power Factor Trend




Figure 4: kWh Units Trend

Table 3 : Additional Payment due to LPF – Annual Summary

S.No	Description	Year
		Mar 19 – Feb 20
1	kVAh-kWh	7600
2	Additional Amount paid in Lakhs	0.58

As the power factor is maintained very well additional amount paid due to low power factor is not significant amount, Auto power factor control may be employed to reduce active power loss and leading power factor.

Recommendation: It is recommended to go for automatic power factor correction equipment

Guidelines:

Capacitors Positioning, Selection
Auto PF correction equipment

Finding 2 : Additional Amount being paid by RVR & JC to APTC due to Higher Contracted Maximum Demand

3.2.2 ADDITIONAL AMOUNT PAID DUE TO HIGHER CONTRACTED MAXIMUM DEMAND (CMD)

The Contracted maximum demand of RVR&JC is 500 KVA quit large as compared to Recorded maximum demand from last 1 year power bills except three months . Minimum demand charges are being paid for all these months.

Table 4 : Additional Payment due to CMD – Annual Summary

Month	KWh	KVAh	Recorded MD	Charged MD	Demand Charges	Total Bill Amount	Additional amount paid
Feb-20	27272	28250	365	400	173546	429604	16454
Jan-20	52322	52772	104	400	49590	608800	140410
Dec-19	80156	22169	390	400	185449.5	814348	4550
Nov-19	62584	10000	510	510	216049	671164	0
Oct-19	98072	10457	543	543	198702	955657	0
Sep-19	82180	10503	518	518	199561.8	828615	0
Aug-19	104476	105828	512	512	243371	1074270	0
Jul-19	101400	103344	561	561	266408.5	1100749	0
Jun-19	67012	67456	464	464	220457	755945	0
May-19	82096	13349	522	522	202088.8	750162	0
Apr-19	105256	107688	555	555	263530	1187969	0
Mar-19	83724	43555	471	471	194275	369900	0




Figure 5 : RVR & JC Recorded KVA Demand Trend




Figure 6 : RVR & JC Additional amount paid due to CMD

Table 5 : Additional Payment due to CMD – Annual Summary

S.No	Description	Duration
		Jan 2019 & Feb 2020
1	Contracted Maximum Demand in KVA	500
2	Recorded Maximum Demand in KVA	365
3	Average Monthly Additional Amount paid in lakhs	0.78
4	Additional Amount paid in Lakhs	1.56

Recommendation: Reduce KVA demand by employing the Energy Efficient devices to reduce Demand and kVAh units consumption simultaneously.

Guidelines:

Deration of CMD
Employing of Energy Efficient Devices

3.3 RVR&JC LIGHTING AND FANS

Lighting used in RVR & JC is energy efficient. However, it is observed that there are still some in 40W and 36W Fluorescent lights, 18W CFL Bulbs and Inefficient fans in use which if replaced may save considerably. The list of light fittings, fans and their usage hours is presented in **Table 6** below. The same may be implemented even in the other areas of usage.

Table 6 : RVR&JC Lighting Load Details

S.No	LOCATION	Tube Light	Tube Light	CFL	CFL	CFL	CFL	LED	LED	LED	FAN	FAN
	Wattage (W)	40	36	5	18	20	72	24	40	60	85	60
1	MAIN Block	308			14			69			147	70
2	LIBRARY and CANTEEN		135		92			20			185	
3	DECINIAL		237		2			60			139	
4	SILVER JUBILEE		157		10			11			153	
5	SHEDs		169		10			2			168	
6	DIGITAL		365		115			1			198	
7	HITECH		239		146			65				282
8	CYBER		156	8	331	18	32	6			181	
9	OTHERS		32		14			21	6	13	34	
Total Count		308	1490	8	734	18	32	255	6	13	1205	352

Finding 3 : Savings by replacing In-efficient 40W old TL with LED Light

3.3.1 SAVINGS BY REPLACING IN-EFFICIENT 40W OLD TL WITH LED LIGHT

Table 7 : Savings by replacing In-efficient 40W old TL with LED Light

S.No	Description	Unit	Value
1	Total No of 40W TL fittings present in Campus	No	308
2	Approx. Avg Monthly Energy Consumption with 40W TL	kWh	1,873
3	Approx. Avg Monthly Energy Consumption with 20W LED	kWh	936
4	Approx. Avg Monthly Energy Savings with 20W LED TL	kWh	936
5	Present cost of kWh	INR	7.65
6	Approx. Monthly Energy Savings with 20W LED in rupees	INR	7,163
7	Approx. Savings per annum in rupees	INR Lakhs	0.86
8	Demand reduction in KVA by opting LED	KVA	5.9
9	Demand reduction by opting LED	INR Lakhs	0.34
10	Total Savings by replacing 40W TL with 20W LED TL	INR Lakhs	1.20
11	Approximate Investment per one 20W LED TL	INR	400
12	Approximate Investment per requirement	INR Lakhs	1.23
13	Approx. Simple payback period	Years	1.0
Remarks			
Replace all the existing old 40W TL with 20W LED TLs to save energy			
8 Hours per day, average of 19 days per month and total 230 days per annum considered			

Recommendation:

Guidelines:

This can be taken up in phased manner

Finding 4 : Savings by replacing In-efficient 36W old TL with LED Light

3.3.2 SAVINGS BY REPLACING IN-EFFICIENT 36W OLD TL WITH LED LIGHT

Table 8 : Savings by replacing In-efficient 36W old TL with LED Light

S.No	Description	Unit	Value
1	Total No of 36W TL fittings present in Campus	No	1,490
2	Approx. Avg Monthly Energy Consumption with 36W TL	kWh	8,153
3	Approx. Avg Monthly Energy Consumption with 20W LED TL	kWh	4,530
4	Approx. Avg Monthly Energy Savings with 20W LED TL	KWh	3,624
5	Present cost of kWh	INR	7.65
6	Approx. Monthly Energy Savings with 20W LED TL in rupees	INR	27,721
7	Approx. Savings per annum in rupees	INR Lakhs	3.33
8	Demand reduction in KVA by opting LED TL	KVA	22.6
9	Demand reduction by opting LED TL	INR Lakhs	1.29
10	Total Savings by replacing 36W TL with LED	INR Lakhs	4.61
11	Approx. Investment per one 20W LED TL	INR	400
12	Approx. Investment per requirement	INR Lakhs	6.0
13	Approx. Simple payback period	Years	1.3
Remarks			
Replace all the existing old 36W TL with 18W LED TLs to save energy			
8 Hours per day, Avg of 19 days per month and total 230 days per annum considered			

Recommendation:

Guidelines:

Change all the TL with LED

Finding 5 : Losses due to In-efficient CFL Bulbs

3.3.3 LOSSES DUE TO IN-EFFICIENT CFL BULBS

Table 9 : Losses due to In-efficient CFL Bulbs

S.No	Description	Unit	Value
1	Total No of CFL bulbs present in Campus	No	734
2	Approx. Avg Monthly Energy Consumption with CFL	kWh	2,008
3	Approx. Avg Monthly Energy Consumption with 9W LED	kWh	1,004
4	Approx. Avg Monthly Energy Savings with 9W LED bulbs	KWh	1,004
5	Present cost of kWh	INR	7.65
6	Approx. Monthly Energy Savings with 9W LED bulbs	INR	7,681
7	Approx. Savings per annum in rupees	INR Lakhs	0.92
8	Demand reduction in KVA by opting LED bulbs	KVA	1.4
9	Demand reduction by opting LED	INR Lakhs	0.08
10	Total Savings by replacing CFL Bulbs with LED bulbs	INR Lakhs	1.00
11	Approx. Investment per one 9W LED bulbs	INR	100
12	Approx. Investment per requirement	INR Lakhs	0.73
13	Approx. Simple payback period	Years	0.7
Remarks			
8 Hours per day, Avg of 19 days per month and total 230 days per annum considered			

Recommendation:

Guidelines:

Go for LED lighting

Finding 6 : Losses due to In-efficient 85W Ceiling Fans

3.3.4 LOSSES DUE TO IN-EFFICIENT 85W CEILING FANS

Table 10 : Losses due to In-efficient 85W Ceiling Fans

S.No	Description	Unit	Value
1	Approx. Total No of 85W Ceiling Fans present in Campus	No	1,205
2	Approx. Monthly Energy Consumption with 85W Fans	kWh	15,569
3	Avg. Wattage of BLDC Ceiling Fan	W	26
4	Approx. Monthly Energy Consumption with BLDC Fans	kWh	4,762
5	Approx. Monthly Energy Savings with BLDC Ceiling Fans	KWh	10,806
6	Present cost of kWh	INR	7.65
7	Approx. Monthly Energy Savings with BLDC Ceiling Fans	INR	82,669
8	Approx. Energy Savings per annum in rupees	INR Lakhs	9.9
9	Demand reduction in KVA by opting BLDC Ceiling fans	KVA	67.5
10	Demand reduction by opting BLDC Ceiling fans	INR Lakhs	3.85
11	Total Savings by replacing existing Ceiling fans with BLDC	INR Lakhs	13.77
12	Approx. Investment per one BLDC Ceiling Fans	INR	3,500
13	Approx. Investment per requirement	INR Lakhs	42.2
14	Approx. Simple payback period	Years	3.06

Remarks

8 Hours per day, Avg of 19 days per month and total 230 days per annum considered
 It can be observed from above tables that the payback is very quick if the Fans are changed to BLDC as shown above.

Recommendation: It is recommended to go for BLDC Ceiling Fans in as the payback is very quick.

Guidelines:

This can be taken up in phased manner

Finding 7 : Losses due to In-efficient 60W Ceiling Fans

3.3.5 LOSSES DUE TO IN-EFFICIENT 60W CEILING FANS

Table 11 : Losses due to In-efficient 60W Ceiling Fans

S.No	Description	Unit	Value
1	Approx. Total No of 60W Ceiling Fans present in Campus	No	352
2	Approx. Monthly Energy Consumption with 60W Fans	kWh	3,210
3	Avg Wattage of BLDC Ceiling Fan	W	26
4	Approx. Monthly Energy Consumption with BLDC Fans	kWh	1,391
5	Approx. Monthly Energy Savings with BLDC Ceiling Fans	KWh	1,819
6	Present cost of kWh	INR	7.65
7	Approx. Monthly Energy Savings with BLDC Ceiling Fans	INR	13,916
8	Approx. Savings per annum in rupees	INR Lakhs	1.7
9	Demand reduction in KVA by opting BLDC Ceiling fans	KVA	11.4
10	Demand reduction by opting BLDC Ceiling fans	INR Lakhs	0.65
11	Total Savings by replacing with BLDC fans	INR Lakhs	2.32
12	Approx. Investment per one BLDC Ceiling Fans	INR	3,500
13	Approx. Investment per requirement	INR Lakhs	12.3
14	Approx. Simple payback period	Years	5.3
Remarks			
8 Hours per day ,Avg of 19 days per month and total 230 days per annum considered			

Recommendation: It is recommended to go for BLDC Ceiling Fans in phased manner.

Guidelines:

This can be taken up in phased manner

Finding 8 : Demand Side Management

3.4 DEMAND SIDE MANAGEMENT ANALYSIS

Table 12 : Savings due to reduction of KVA Demand

S.No	Description	Units	Value
1	Existing Lighting Kw	kW	85.6
2	Existing KVA Demand with Lighting	KVA	90.1
3	New Lighting Kw by opting LED	kW	42.6
4	New KVA Demand with LED Lighting	KVA	44.8
5	Existing Ceiling Fans Kw	kW	124
6	Existing KVA Demand with Ceiling Fans	KVA	130
7	New Ceiling Fans Kw by opting BLDC Fans	kW	40.5
8	New KVA Demand by opting BLDC Fans	KVA	42.6
9	Total Existing KVA demand with Lighting and Fans	KVA	220
10	Total New KVA Demand with Lighting and Fans	KVA	87
11	KVA Demand Difference	KVA	133
12	Total New KVA demand with 80% diversity	KVA	106
13	Approx. Energy Savings per Annum with LED Lighting	kWh	69445
14	Approx. Energy Savings per Annum with BLDC Fans	kWh	151506
15	Total Approx. Energy Savings per Annum	kWh	220951
16	Total Approx. Energy Savings per Annum	INR Lakhs	16.90
17	Approx. Monthly Savings by Reduction of Demand	INR Lakhs	0.50
18	Annual Savings by Reduction of KVA demand	INR Lakhs	6.05
19	Net Savings per Annum	INR Lakhs	22.96
20	Total Investment for Lighting modification	INR Lakhs	7.92
21	Total Investment for Ceiling Fans modification	INR Lakhs	55
22	Net Investment	INR Lakhs	62
23	Average Simple Payback Period	Years	2.72

Recommendation: It is recommended to reduce the Demand immediately by employing BLDC Ceiling Fans to save about 6 Lakhs annually.

Finding 9 : Un-Balanced Loading on Transformers

3.5 ANALYSIS OF FEEDERS WITH POWER ANALYZERS

3.5.1 ANALYSIS OF TRANSFORMERS FEEDERS WITH POWER ANALYZER

A physical observation is made on Transformers feeders by placing power analyser. The meters are set to record all the electrical parameters like voltage, current, power, frequency, reactive power, power factor and Harmonic etc.

Data is collected at an interval of 20 second for 15 min each feeder for precise analysis. During the same time readings of APTC Yard meter and PCC Panel board meters noted and used for further analysis .

Table 13 : Power Analyzer readings of Transformer Feeders

S.No	Trend	IN	IR	IY	IB	V Avg	U Avg	I THD	V THD	KW	KVAR	KVA	PF
1	200KVA Transformer Main Block	42	152	157	164	226	393	5.0%	2.7%	116	29	116	0.96
2	315KVA Transformer SJB Block	27.4	360	342	348	229	397	4.0%	2.4%	243.40	35	247	0.99
3	315KVA Transformer CYBER Block	116	349	254	304	231	400	11.4%	2.5%	206.60	59.3	213	0.96

Table 14 : Loading of Transformer Feeders

S.No	Description	Location	Rated KVA	Max Recorded KVA	% Loading on Transformer
1	315KVA T/F	315KVA Transformer CYBER Block and Digital Block	315	216.4	69%
2	315KVA T/F	315KVA Transformer SJB Block and Hi-tech Block	315	286.6	91%
3	200KVA T/F	200KVA Transformer Main Block	200	134.1	67%

Recommendation: As observed from the above table, it is observed that the loading on the 315KVA SJB and Hitech Block feeder is almost above 90% and need to balance the load. Need to go for single transformer of higher capacity or synchronize the three transformers

Finding 10 : Un-Balanced Loading on Feeders

3.5.2 ANALYSIS OF DISTRIBUTION FEEDERS WITH POWER ANALYZER

A physical observation is made on distribution feeders by placing power analyser on campus working time with all the connected load for 30 minutes on each feeder . The meters are set to record all the electrical parameters like voltage, current, power, ferquency, reactive power, power factor and Harmonic etc.

Table 15 : Power Analyzer readings of the MCC Feeders

S.No	Trend	IN	IR	IY	IB	V Avg	U Avg	I THD	V THD	KW	KVAR	KVA	PF
1	CYBER	45	256	210	232	241	416	3%	2.00%	170	52	175	0.95
2	DIGITAL	77	78	46	114	240	417	4%	2%	52	17	49	0.86
3	HITECH	75	144	143	170	241	419	3%	2%	83	42	96	0.90
4	Main Block	17	177	158	156	226	393	2%	1%	122	30	126	0.97
5	SJB	28	253	256	228	231	401	5%	3%	179	27	181	0.99

Table 16 : Un-Balanced loading of distribution Feeders

S.No	Description	Location	Observed Neutral Current	Observed R Phase Current	Observed Y Phase Current	Observed B Phase Current
1	CYBER	CYBER Block	45.4	255.6	210.4	231.7
2	DIGITAL	DIGITAL Block	76.7	78.1	46	114.1
3	HITECH	HITECH Block	75	144	143	170
4	Main Block	Main Block	16.6	176.7	157.5	155.9
5	SJB Block	Silver Jubilee Block	27.8	253.3	255.6	227.6

From the above table it is observed that the loading on the three phases is unbalanced for highlited feeders and need to balance the load in each phase to minimise the lossess.

Recommendation: It is recommended to balance the load in each phase to minimize the losses and rearrange/replace the capacitor banks.

Finding 11 : Absence of Energy Monitoring and Control Mechanism

3.5.3 ELECTRICAL ENERGY MANAGEMENT AND CONTROL

As observed that energy consumed is about average of 80 thousand units.

RVR&JC has about 5 main feeders and approx. 60 numbers of sub feeders have no energy monitoring system/meters. Even the main PCC feeders at Power House does not have energy meters which may not cost more than 6 thousand each.

It is known fact that the energy that is not monitored can not be controlled and that cannot be controlled cannot be conserved.

Recommendation: Feeder wise energy monitoring system with MFM meters and monitoring of all the parameters like MD, PF, kVAh, kWh and kVARh, etc., shall be established.

Guidelines:

Install Energy meters to Selective Feeders with connectivity MD Controller

Finding 12 : Absence of Energy Balance Mechanism

3.5.4 ELECTRICAL ENERGY BALANCE

Energy balance is the process in which supplied energy is matched to the consumed energy. It is the most essential element in Energy Audit to identify the losses.

RVR&JC monthly consumption is about 80 thousand kVAh and approximate bill value is Rs 5-8 Lakhs which is quite a huge amount.

There should be proper mechanism to automatically balance the energy supplied versus consumed based on usage. Feederwise and Buildingwise Energy balance helps plug the wastage and conserve energy.

Recommendation: Feeder wise energy monitoring system with automatic energy balance on daily basis shall be established.

Guidelines:

Install feeder wise Energy Monitoring system with automatic energy balance

Finding 13 : Capacitor Banks Health

3.6 CAPACITOR BANK HEALTH

RVR & JC has 250 Kvar capacitor banks. Power analyser is used and currents are measured and presented in the table below

Table 17 : Capacitor Banks health

S.No	Rating of capacitor bank (kVAr)	Location of Capacitors	Sub Location	Rated Current			Observed Current		
1	25	CYBER BLOCK	Main panel board	32.8	32.8	32.8	16	22	8
2	25	CYBER BLOCK	Main panel board	32.8	32.8	32.8	32	30	33
3	25	CYBER BLOCK	Sub panel board	32.8	32.8	32.8	32	32	33
4	25	DIGITAL	Main panel board	32.8	32.8	32.8	8	8	15
5	25	HITECH BLOCK	Main panel board	32.8	32.8	32.8	0	0	0
6	25	MAIN BLOCK	Main panel board	32.8	32.8	32.8	0	0	0
7	25	DECINIAL	Main panel board	32.8	32.8	32.8	32	33	31
8	25	DECINIAL	Main panel board	32.8	32.8	32.8	32	32	30
9	25	SJB BLOCK	seminar hall	32.8	32.8	32.8	27	17	12
10	25	SJB BLOCK	Main panel board	32.8	32.8	32.8	13	8	7

It is observed that the currents carried by banks are almost zero in some cases, nearer to rated values.

Guidelines:

Design and Install proper rating of Capacitor to improve Power Factor

Finding 14 : Expansion of Solar Power Plant Vs BLDC Ceiling Fans
3.7 EXPANSION OF SOLAR PLANT VS REPLACEMENT OF CEILING FANS WITH BLDC CEILING FANS

A simple analysis and working are presented to expand solar power plant verses replacement of ceiling fans with BLDC ceiling fans.

Table 18 : Analysis of Solar Power Plant Expansion

S.No	Description	Units	Value
1	Total KWh Units Generated by 100Kwp Solar Plant	KWh/Annum	146000
2	Total Approximate Energy Savings per Annum	INR Lakhs	11
3	100 kWp Solar On-Grid Power Plant Cost	INR Lakhs	51
4	Other Expenses @15% of project cost	INR Lakhs	7.65
5	Annual maintenance charges @ 15% of project cost	INR Lakhs	7.65
6	Total Cost of Project	INR Lakhs	66
7	Average Simple Payback Period	Years	5.94

Table 19 : Analysis of In-Efficient Ceiling Fans with BLDC Ceiling Fans

S.No	Description	Units	Value
1	Approx. Energy Savings per Annum with BLDC Fans	KWh	151506
2	Total Approximate Energy Savings per Annum	INR Lakhs	11.5
3	Demand Reduction in KVA with BLDC fans	KVA	83.1
4	Demand charges reduction with BLDC fans	INR Lakhs	4.74
5	Net Savings per annum by replacing with BLDC Fans	INR Lakhs	16.3
6	Total Investment for Ceiling Fans modification	Lakhs	55
7	Average Simple Payback Period	Years	3.3

Recommendation: It is recommended to go with BLDC ceiling fans to reduce demand, also payback and execution time is quick. where as in expansion of solar power plant it requires more Land and demand may not be reduced due to risk of high MD during low generation due to weather conditions.

Finding 15 : Savings with Dual Inverter Type Air Conditioners

3.8 AIR CONDITIONING

Total Connected Air Conditioner Load of RVR&JC is about 286 Tons of Split and Window air conditioners and 254 Tons of Cassette and Duct air Conditioners Building wise Air Conditioners present in campus given in the below tables. As the Split and Window Air Conditioners are of about 10 - 8 years old, there is a chance of losses.

Building wise and Tonnage wise Split and Window Air Conditioners present in the whole campus given in the below tables.

Table 20 : Summary of Split and Window Air Conditioners building wise

S.No	Department	1 Ton	1.5 Ton		2 Ton	
		Split	Window	Split	Window	Split
1	CSE (Including guest rooms, seminar halls)	2	2			11
2	ECE (Including seminar hall, dining room)		7			18
3	EEE (including power room)		2	1		7
4	Chemical			2		9
5	Exam section special		12	1		2
6	SD Cell					5
7	Civil Engineering including SM lab			1		6
8	IT					1
9	Library			2		12
10	MCA					1
11	Mechanical Engineering (Including E-class room, Seminar Hall and Guest room and Metrology lab)			1		28
12	Placement (interview room, guest room, dining room, dean)	6		1		3
13	Principal Room					2
14	Management Room					2
15	Secretary and correspondent					
16	Dispensary (including women's NCC room)		1	1		2
17	City center	1		4		2
18	Total	9	24	14	0	110

Table 21 : Savings with Dual Inverter Type Air Conditioners

S.No	Description	Units	Value
1	Total No of Split and Window Air Conditioners	Nos	158
2	Running Kw with existing Air Conditioners	Kw	364.3
3	Existing KVA Demand with Air Conditioners	KVA	310
4	Reduction in KVA Demand with Dual Inverter Air Conditioners @30% of consumption	KVA	93
5	Annual Savings by Reduction of KVA demand	INR Lakhs	5.3
6	Approx. Annual Energy Consumption with Existing ACs	kWh	335156
7	Annual Energy Savings by replacing with Dual Inverter Air Conditioners @30% of consumption	kWh	100547
8	Annual Energy Savings by replacing with Dual Inverter Air Conditioners @30% of consumption	INR Lakhs	7.7
9	Total Savings	INR Lakhs	13
10	Approx. Investment	INR Lakhs	100
11	Simple Payback period	Years	7.7

Recommendation: It is recommended to go with Dual Inverter type ACs to reduce demand in phased manner. The machines with running hours more than 6 hours may be changed first.

